

Facility and Pumproom Checklist:

Walk through bathrooms:

- Heaters working
- Showers working
- Every stall has toilet paper and seat covers
- Paper towels and soap

Lap Pool:

- Railings are secure
- Check for potential hazards
- Functioning equipment: hook, tube, net, stand, dive platforms
- Loungers, tables, chairs, umbrellas in working order
- Capacity sign is legible

Splash Pad/ Kid Pool:

- Trash cans empty
- Grates are in ground properly secure
- Cleanliness
- Loungers, tables, chairs, umbrellas in working order

Rec Pool:

- Railings are secure
- Check for potential hazards
- Functioning equipment: hook, tube, net, stand, clock
- Loungers, tables, chairs, umbrellas in working order
- Capacity sign is legible

Pumproom:

- Scene safety: water on ground, unusual sounds
- Low water alarms
- Acid Room: leaks/bubbles in lines or pumps, look down: dry under grate, shut door
- Chlorine Room: leaks/bubbles in lines or pumps, look down: dry under grate, shut door
- Red alarms on controllers: troubleshoot or call manager
- Flow rates & influent/ effluent within parameters
- Heaters functional
- Chem check & record**
- Add sodium bicarbonate if needed: refer to chem cheat sheet